

FK06 DialSet®

LOW LEAD PRESSURE REGULATING FILTER COMBINATION

SUBMITTAL SHEET

Job Name	
Engineer	
Mechanical Contractor	
Contractor's P.O. No.	
Representative	
Notes	

Model(s)				
	Qty.	Notes		
	Qty.	Notes		
	Qty	Notes		
Approval				
Service				
Tag No.				

APPLICATION



The Honeywell FKO6 DialSet Pressure Regulating Filter Combination is a high-quality pressure regulating valve and rinsable filter that maintains a constant outlet pressure over a wide range of inlet supply pressures and ensures a continuous supply of filtered water. It is suitable for potable water and irrigation applications. The downstream pressure adjustment dial eliminates the need for a pressure gauge when adjusting the pressure setting (static pressure only).

SPECIFICATIONS

 $\textbf{Model:} \ \mathsf{FK06} \ \mathsf{DialSet} \ \mathsf{Pressure} \ \mathsf{Regulating} \ \mathsf{Filter} \ \mathsf{Combination}$

Regulator Mechanism: Fabric-reinforced diaphragm.

Filter Mechanism: Stainless steel 50 micron rinsable filter insert.

Seat Design: Balanced single seat construction.

Inlet Pressure (Maximum): 250 psi maximum.

Reduced Pressure Range: 25 to 90 psi (1/2 in. to 2 in.).

Outlet Pressure: Factory set at 60 psi (414 kPa).

Dial Calibration: ± 4 psi.

Differential: 14.5 psi minimum (inlet to outlet).

Fluid Temperature (Maximum):

Water: 104° F (40° C).

Ambient Temperature Range: $33^{\circ}\,F$ to $140^{\circ}\,F$ (1° C to $60^{\circ}\,C$).

Pipe Sizes Available:

3/4 in., 1 in., 1-1/4 in. available.

Connections: Can be configured as female thread-by-thread, double-union, NPT

threaded or sweat.

 $\textbf{Low Lead Content:} < 0.25\% \ \text{Lead}.$

 $\textbf{Gauge Tap: } 1/4" \ \text{NPT}.$

Approvals:

ASSE 1003 Listed CSA Certified NSF 61 Compliant

MATERIALS

Body: Brass

Internal Parts: Stainless steel and engineered plastics Regulator Mechanism: Fabric-reinforced diaphragm

*Lead Free Plumbing Code Compliance: The wettable surfaces of lead free models contain less than 0.25% of lead by weighted average.

DIMENSIONS

Model Number	Pipe Size	Dimensions, Approximate		
	Inch	Inch (H x L)	mm (H x L)	
	Doub	ole-Union Sweat		
FK06-101-DUS-LF	3/4"	9-3/4" x 5-13/64"	247 x 132	
FK06-102-DUS-LF	1"	11-9/16" x 6-17/32"	293 x 166	
FK06-103-DUS-LF	1-1/4"	11-9/16" x 7-1/8"	293×181	
	Double	e-Union Threaded		
FK06-101-DUT-LF	3/4"	9-3/4" x 5-13/64"	247 x 132	
FK06-102-DUT-LF	1"	11-9/16" x 6-1/16"	293 x 154	
FK06-103-DUT-LF	1-1/4"	11-9/16" x 6-47/64"	293 x 171	



WATER CAPACITIES

The suitability of a given regulator size is dependent on the pressure requirements where it will operate. For the pressure regulator valve size required for a specific installation, determine the following:

- 1. Pressure differential between inlet and outlet pressure in pounds per square inch (psi),
- 2. Capacity in gallons per minute, and
- 3. Allowable reduced pressure falloff in psi. Given these variables, use Table 2 to determine the proper size pressure regulator valve for your application.

Example: An installation has 135 psi inlet pressure, 60 psi outlet pressure (75 psi pressure differential). If a 15 gpm capacity is required with only 10 psi falloff allowable, a 3/4 in. FK06 is required.

Pressure	Reduced Pressure Falloff (PSI)	Pressure Differential Between Inlet and Outlet.				
Regulator Valve Size		25 psi	50 psi	75 psi	100 psi or more	
		Flow Capacity (US gpm)	Flow Capacity (US gpm)	Flow Capacity (US gpm)	Flow Capacity (US gpm)	
	6	8.2	8.85	7.95	6.63	
3/4"	10	17.17	21.05	25.23	26.33	
	15	19.86	25.14	29.32	32.85	
	20	21.27	26.42	30.42	33.82	
1"	6	11.18	11.23	9.51	9.11	
	10	18.01	18.98	17.39	16.78	
	15	25.67	28.14	28.71	26.9	
	20	30.69	34.7	36.19	35.05	
	6	7.53	6.34	7.26	7.13	
1-1/4"	10	20.25	17.88	15.15	14	
	15	33.02	34.87	32.63	29.68	
	20	40.07	44.29	46.01	34.61	

FK06 FIXTURE UNIT

Flow rates based on submittal sheet FK06, based on flush tank systems with a 15 psi fall-off defined by IAPMO/ANSI UPC 1-2009.

Size	l/s	GPM	Fixture Units
3/4"	1.58	25.14	40
1"	1.77	28.14	48
1-1/4"	2.19	34.87	70

Capacities are based on a 100 psi supply pressure and a difference of 50 psi or more between the initial supply pressure and the reduced no-flow pressure. Check local water pressures before selection.

